

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: RAW SURFACE WATER ENTRY POINT - CHESTNUT (WSF ID: 00500)

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - CHESTNUT (1)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - CHESTNUT (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - CHESTNUT (1)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Surface Water Pesticides (RSOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - CHESTNUT (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Water System Facility: RAW SURFACE WATER ENTRY POINT - EUREKA (WSF ID: 00501)

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - EUREKA (1)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - EUREKA (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - EUREKA (1)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: **RAW SURFACE WATER ENTRY POINT - EUREKA (WSF ID: 00501)**

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW EP - EUREKA (1)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (0999)	10 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Asbestos (1094)	2 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		

Total Coliform (3100)	10 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Disinfectant Byproducts - TTHM & HAA5 (DBP)	2 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SPRING HILL P.S (SWS09)	10/1/18 - 12/31/18	12/1-12/31	Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		2 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/19 - 3/31/19	3/1-3/31	Complete
	4/1/19 - 6/30/19	6/1-6/30	
	7/1/19 - 9/30/19	9/1-9/30	
24 DODGINGTOWN RD (SWS10)	10/1/18 - 12/31/18	12/1-12/31	Complete
	1/1/19 - 3/31/19	3/1-3/31	Complete
	4/1/19 - 6/30/19	6/1-6/30	
	7/1/19 - 9/30/19	9/1-9/30	

Lead And Copper (PBCU)		40 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/18 - 12/31/18		Complete
	1/1/19 - 6/30/19		
	7/1/19 - 12/31/19		

Physical Parameters (PPS)		10 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: **ENTRY POINT 1 - CHESTNUT RIDGE (WSF ID: 00700)**

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/17 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: ENTRY POINT 1 - CHESTNUT RIDGE (WSF ID: 00700)

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CHESTNUT RIDGE (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Water System Facility: ENTRY POINT 2 - EUREKA (WSF ID: 00701)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: ENTRY POINT 2 - EUREKA (WSF ID: 00701)

Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EUREKA (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Water System Facility: ENTRY POINT - MAPLE AVE WELLS (WSF ID: 00702)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MAPLE AVE WELLS (3)	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MAPLE AVE WELLS (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MAPLE AVE WELLS (3)	1/1/19 - 12/31/21		
	1/1/22 - 12/31/24		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MAPLE AVE WELLS (3)	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: ENTRY POINT - MAPLE AVE WELLS (WSF ID: 00702)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MAPLE AVE WELLS (3)	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		

Water System Facility: EUREKA FILTER PLANT (WSF ID: 10)

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COMBINED FILTER EFFLUENT - EUREKA (5)	11/1/18 - 11/30/18		Out of Service
	12/1/18 - 12/31/18		Out of Service
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		Out of Service
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: CHESTNUT RIDGE RESERVOIR (WSF ID: 2001)

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CHESTNUT RIDGE RES (1)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CHESTNUT RIDGE RES (1)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: CHESTNUT RIDGE RESERVOIR (WSF ID: 2001)

Total Organic Carbon (2920)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: EUREKA LAKE (WSF ID: 2003)

Total Alkalinity (1927)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EUREKA LAKE (1)	11/1/18 - 11/30/18		Out of Service
	12/1/18 - 12/31/18		Out of Service
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Total Organic Carbon (2920)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EUREKA LAKE (1)	11/1/18 - 11/30/18		Out of Service
	12/1/18 - 12/31/18		Out of Service
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Water System Facility: MAPLE AVE WELL 1A (WSF ID: 60721)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: **MAPLE AVE WELL 1A (WSF ID: 60721)**

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MAPLE AVE - WELL 1A (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: **MAPLE AVE WELL 2A (WSF ID: 60723)**

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MAPLE AVE - WELL 2A (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: **CHESTNUT RIDGE FILTER PLANT (WSF ID: 9)**

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COMBINED FILTER EFFLUENT- CHESTNUT RIDGE (5)	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT 1 - CHESTNUT RIDGE (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily	
Start Date: 9/1/2003				
		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		11/1/2018 - 11/30/2018		N
		12/1/2018 - 12/31/2018		N
		1/1/2019 - 1/31/2019		N
		2/1/2019 - 2/28/2019		N
		3/1/2019 - 3/31/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Water System Facility: ENTRY POINT 1 - CHESTNUT RIDGE (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 9/1/2003			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		4/1/2019 - 4/30/2019	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 9/1/2003			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	N
		12/1/2018 - 12/31/2018	N
		1/1/2019 - 1/31/2019	N
		2/1/2019 - 2/28/2019	N
		3/1/2019 - 3/31/2019	
		4/1/2019 - 4/30/2019	

Water System Facility: ENTRY POINT 2 - EUREKA (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 9/1/2003			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	N
		12/1/2018 - 12/31/2018	N
		1/1/2019 - 1/31/2019	N
		2/1/2019 - 2/28/2019	N
		3/1/2019 - 3/31/2019	
		4/1/2019 - 4/30/2019	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 9/1/2003			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		11/1/2018 - 11/30/2018	N
		12/1/2018 - 12/31/2018	N
		1/1/2019 - 1/31/2019	N
		2/1/2019 - 2/28/2019	N
		3/1/2019 - 3/31/2019	
		4/1/2019 - 4/30/2019	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			3,300				

Towns Served: BETHEL, DANBURY

Water System Facility: ENTRY POINT - MAPLE AVE WELLS (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2017			
Compliance History:	Monitoring Period	Operating Limit	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 7/1/2017			
Compliance History:	Monitoring Period	Operating Limit	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Water System Facility: EUREKA FILTER PLANT (WSFID: 10)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2003			
Compliance History:	Monitoring Period	Operating Limit	Monitoring Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	12/1/2018 - 12/31/2018	Y	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2005			
Compliance History:	Monitoring Period	Operating Limit	Monitoring Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	2/1/2019 - 2/28/2019	Y	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Water System Facility: EUREKA FILTER PLANT (WSFID: 10)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline 11/1/2018 - 11/30/2018	n/a	Y
	Offline 12/1/2018 - 12/31/2018	n/a	Y
	Offline 1/1/2019 - 1/31/2019	n/a	Y
	2/1/2019 - 2/28/2019	Y	Y
	Offline 3/1/2019 - 3/31/2019	n/a	Y
	4/1/2019 - 4/30/2019		

Water System Facility: CHESTNUT RIDGE FILTER PLANT (WSFID: 9)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2003			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2005			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	11/1/2018 - 11/30/2018	Y	Y
	12/1/2018 - 12/31/2018	Y	Y
	1/1/2019 - 1/31/2019	Y	Y
	2/1/2019 - 2/28/2019	Y	Y
	3/1/2019 - 3/31/2019	Y	Y
	4/1/2019 - 4/30/2019		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2010	
SUBMIT TTHM OPERATIONAL EVALUATION RPT	6/30/2016	
LT2 - SUBMIT BIN CLASSIFICATION	3/30/2019	
LT2 - SUBMIT BIN CLASSIFICATION	3/30/2019	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
0001	EMERGENCY INTERCONNECTION							
00500	RAW SURFACE WATER ENTRY POINT - CHESTNUT	1	RAW EP - CHESTNUT	A				
00501	RAW SURFACE WATER ENTRY POINT - EUREKA	1	RAW EP - EUREKA	A				
00502	RAW WELLFIELD ENTRY POINT	2	RAW EP - WELLFIELD	A				
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		ALCS61	36 HIGHLAND AVENUE	A	Y	1		
		ALCS62	78 KINGSWOOD DRIVE	A	Y	2		
		ALCS63	92 KINGSWOOD DRIVE	A	Y	2		
		ALCS64	98 KINGSWOOD DRIVE	A	Y	2		
		ASWS11	10 NASHVILLE RD	A	Y			
		ASWS12	12 MANSFIELD ST	A	Y			
		ASWS13	6 SYMPAUG PARK RD	A	Y			
		ASWS14	17 TROWBRIDGE DR	A	Y			
		ASWS15	81 GREENWOOD AVE	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		GWS02	24 GRASSEY PLAIN STE	A	Y			
		GWS03	1 SCHOOL ST	A	Y			
		GWS04	600 WHITLESEY DR	A	Y			
		GWS05	185 GRASSEY PLAIN ST	A	Y			
		GWS06	36 SOUTH ST	A	Y			
		GWS07	1 KINGSWOOD DR	A	Y			
		GWS08	SUMMIT ROAD	A	Y			
		LC53 - 34 I	GENERATED BY BATCH	A	Y			
		LCS 22	GENERATED BY BATCH	A	Y			
		LCS 23	GENERATED BY BATCH	A	Y			
		LCS 26	GENERATED BY BATCH	A	Y			
		LCS 27	GENERATED BY BATCH	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Water System Facility and Sampling Point Inventory

<i>Water System</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		LCS 28	GENERATED BY BATCH	A	Y			
		LCS 29	GENERATED BY BATCH	A	Y			
		LCS 30	GENERATED BY BATCH	A	Y			
		LCS 33	GENERATED BY BATCH	A	Y			
		LCS 34	GENERATED BY BATCH	A	Y			
		LCS 35	GENERATED BY BATCH	A	Y			
		LCS 36	GENERATED BY BATCH	A	Y			
		LCS 38	GENERATED BY BATCH	A	Y			
		LCS 39	GENERATED BY BATCH	A	Y			
		LCS 40	GENERATED BY BATCH	A	Y			
		LCS 42	GENERATED BY BATCH	A	Y			
		LCS 44	GENERATED BY BATCH	A	Y			
		LCS 45	GENERATED BY BATCH	A	Y			
		LCS 46	GENERATED BY BATCH	A	Y			
		LCS 48	GENERATED BY BATCH	A	Y			
		LCS 49	GENERATED BY BATCH	A	Y			
		LCS 50	GENERATED BY BATCH	A	Y			
		LCS 51	GENERATED BY BATCH	A	Y			
		LCS 52	GENERATED BY BATCH	A	Y			
		LCS 53	GENERATED BY BATCH	A	Y			
		LCS 55	GENERATED BY BATCH	A	Y			
		LCS 56	GENERATED BY BATCH	A	Y			
		LCS 58	GENERATED BY BATCH	A	Y			
		LCS 59	GENERATED BY BATCH	A	Y			
		LCS 60	GENERATED BY BATCH	A	Y			
		LCS21	9 SHARON CT	A	Y	1		
		LCS22	1 VERA ST	A	Y	1		
		LCS22 - 1 V	GENERATED BY BATCH	A	Y			
		LCS23	19 SHARON CT	A	Y	1		
		LCS23 19 SH	GENERATED BY BATCH	A	Y			
		LCS24	80 KINGSWOOD DR	A	Y	2		
		LCS25	76 KNOLLWOOD DR	A	Y	2		
		LCS26	2 PUTNAM PARK RD	A	Y	1		
		LCS27	40 NASHVILLE RD	A	Y	1		
		LCS28	76 KINGSWOOD DR	A	Y	2		
		LCS28 - 76	GENERATED BY BATCH	A	Y			
		LCS29	55B KNOLLWOOD DRIVE	A	Y	2		
		LCS30	80 HOYT'S HILL ROAD	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		LCS31	83 NASHVILLE ROAD	A	Y	1		
		LCS32	5 MAIN STREET #24	A	Y	2		
		LCS33	91 NASHVILLE ROAD	A	Y	1		
		LCS34	12 HIGHVIEW TERRACE	A	Y	1		
		LCS34 - 12	GENERATED BY BATCH	A	Y			
		LCS35	21 SHARON COURT	A	Y	1		
		LCS36	14 MILWAUKEE AVENUE	A	Y	1		
		LCS37	7 KAYVIEW AVENUE	A	Y	1		
		LCS38	49 NATURE VIEW TRAIL	A	Y	2		
		LCS39	8 HIGHVIEW TERRACE	A	Y	1		
		LCS40	51 NATURE VIEW TRAIL	A	Y	2		
		LCS41	66 GREENWOOD AVENUE	A	Y	1		
		LCS42	30 HIGHLAND AVENUE	A	Y	1		
		LCS42 - 30	GENERATED BY BATCH	A	Y			
		LCS43	24B RESERVOIR STREET	A	Y	1		
		LCS44	10 WHITLOCK AVENUE	A	Y	1		
		LCS45	53A KNOLLWOOD DRIVE	A	Y	2		
		LCS46	57 KNOLLWOOD DRIVE	A	Y	2		
		LCS47	12 BENSON ROAD	A	Y	1		
		LCS48	43B PLUMTREES ACRES	A	Y	2		
		LCS48 - 43B	GENERATED BY BATCH	A	Y			
		LCS49	45B PLUMTREES ACRES	A	Y	2		
		LCS50	7 MAIN STREET #2	A	Y	2		
		LCS51	27 DEER RUN TRAIL	A	Y	2		
		LCS52	33 DEER RUN TRAIL	A	Y	2		
		LCS53	34 IDLEWOOD DRIVE	A	Y	2		
		LCS54	38 IDLEWOOD DRIVE	A	Y	2		
		LCS55	44 IDLEWOOD DRIVE	A	Y	2		
		LCS56	52 NATURE VIEW TRAIL	A	Y	2		
		LCS56 - 52	GENERATED BY BATCH	A	Y			
		LCS57	60 NATURE VIEW TRAIL	A	Y	2		
		LCS58	55 KINGSWOOD DRIVE	A	Y	2		
		LCS58 - 55	GENERATED BY BATCH	A	Y			
		LCS59	65 KINGSWOOD DRIVE	A	Y	2		
		LCS59 - 65	GENERATED BY BATCH	A	Y			
		LCS60	71 KINGSWOOD DRIVE	A	Y	2		
		SWS01	RESERVOIR ST P.S.	A	Y			
		SWS08	44 CHESTNUT ST	I	Y			Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		SWS09	SPRING HILL P.S	A	Y			Y
		SWS10	24 DODGINGTOWN RD	A	Y			Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT 1 - CHESTNUT RIDGE	3	EP - CHESTNUT RIDGE	A				
00701	ENTRY POINT 2 - EUREKA	3	EP - EUREKA	A				
00702	ENTRY POINT - MAPLE AVE WELLS	3	EP - MAPLE AVE WELLS	A				
10	EUREKA FILTER PLANT	3	ENTRY POINT - EUREKA	A				
		5	COMBINED FILTER EFFL	A				
1370	MAPLE AVE WELL 1	2	MAPLE AVE WELL 1	A				
1371	MAPLE AVE WELL 2	2	MAPLE AVE WELL 2	A				
1625	MAPLE AVE WELLS							
2001	CHESTNUT RIDGE RESERVOIR	1	CHESTNUT RIDGE RES	A				
2002	MOUNTAIN POND	1	MOUNTAIN POND	A				
2003	EUREKA LAKE	1	EUREKA LAKE	A				
30013	EUREKA LAKE RESERVOIR INTAKE							
30014	CHESTNUT RIDGE RESERVOIR INTAKE							
51610	CHESTNUT RIDGE CLEARWELLS							
51612	EUREKA WTP CLEARWELLS							
51616	HOYTS HILL BOOSTER STATION							
51618	HOYTS HILL STORAGE TANK							
51620	HOYTS HILL HYDROPNEUMATIC TANK							
51621	THE SUMMIT - LOWER PS							
51622	THE SUMMIT - UPPER PS							
59921	SOUTH STREET PUMP STATION							
60721	MAPLE AVE WELL 1A	2	MAPLE AVE - WELL 1A	A				
60723	MAPLE AVE WELL 2A	2	MAPLE AVE - WELL 2A	A				
61053	EUREKA LAKE WATER STORAGE TANK							
61176	BRIAR CLIFF PUMP STATION							
9	CHESTNUT RIDGE FILTER PLANT	3	ENTRY POINT - CHESTN	A				
		5	COMBINED FILTER EFFL	A				

Certified Operator Information

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090011	BETHEL WATER DEPT			C	9,507	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3,300				

Towns Served: BETHEL, DANBURY

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
CURTIS, KELLY D.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2019
MCCOLLAM, CHRISTOPHER C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2021 6/30/2019
COOK, NORMAN G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2021
KNAPP, EDWARD H.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2020
BENZING, RICHARD A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2021 3/31/2022

Water System Facility: CHESTNUT RIDGE FILTER PLANT (WSF ID: 9)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KNAPP, EDWARD H.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2020
MCCOLLAM, CHRISTOPHER C.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019 12/31/2021
BECHTOLD, JUSTIN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2020 6/30/2021

Water System Facility: EUREKA FILTER PLANT (WSF ID: 10)

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KNAPP, EDWARD H.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2020
MCCOLLAM, CHRISTOPHER C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2021 6/30/2019
BECHTOLD, JUSTIN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2021 9/30/2020

Water System Facility: MAPLE AVE WELLS (WSF ID: 1625)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KNAPP, EDWARD H.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2020
MCCOLLAM, CHRISTOPHER C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2021 6/30/2019
BECHTOLD, JUSTIN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2020 6/30/2021

Contact Information

Name		Organization		Job Title		
Mr. Thomas F. Villa		Town of Bethel		Public Utilities Dir		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
1 School Street				Bethel	CT	06801
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0090011	BETHEL WATER DEPT	C	9,507	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
			3,300		
Towns Served: BETHEL, DANBURY					
203-794-8557		203-794-8767		203-313-9982	
Contact Role(s):		Administrative Contact			
Name		Organization		Job Title	
Mr. Matthew S. Knickerbocker		Town of Bethel		First Selectman	
Mailing Address Line One		Mailing Address Line Two		City	State
Cjh Municipal Center		1 School Street		Bethel	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-794-8501		203-778-7502	203-482-6731		firstselectman@bethel-ct.gov

Contact Role(s):	Legal Contact
------------------	---------------

- Please note the following:**
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
 2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0098011	AQUARION WATER CO OF CT-CHIMNEY HEIGHTS			C	1,554	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				582	53		2	

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/13 - 12/31/21		
Total Haloacetic Acids (2456)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BIG Y CHIM (04725)	1/1/18 - 12/31/18	8/3-8/9	Complete
	1/1/19 - 12/31/19	8/3-8/9	
	1/1/20 - 12/31/20	8/3-8/9	
Total Trihalomethanes (2950)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BERKSHIRE INN - CHIM (04724)	1/1/18 - 12/31/18	8/3-8/9	Complete
	1/1/19 - 12/31/19	8/3-8/9	
	1/1/20 - 12/31/20	8/3-8/9	
Total Coliform (3100)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Lead And Copper (PBCU)		10 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/22	6/1-9/30	
Physical Parameters (PPS)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0098011	AQUARION WATER CO OF CT-CHIMNEY HEIGHTS			C	1,554	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				582	53		2	

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)		2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	6/1/19 - 6/30/19			
	7/1/19 - 7/31/19			
	8/1/19 - 8/31/19			
	9/1/19 - 9/30/19			
	10/1/19 - 10/31/19			

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0098011	AQUARION WATER CO OF CT-CHIMNEY HEIGHTS			C	1,554	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				582	53		2	

Towns Served: BETHEL, DANBURY

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		

Water System Facility: WELL 1 (WSF ID: 1205)

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.7 MG/L	Daily
Start Date: 6/1/2012	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 10 MG/L	2
Start Date: 1/1/2004	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2018 - 11/30/2018		N
	12/1/2018 - 12/31/2018		N
	1/1/2019 - 1/31/2019		N
	2/1/2019 - 2/28/2019		N
	3/1/2019 - 3/31/2019		
	4/1/2019 - 4/30/2019		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0098011	AQUARION WATER CO OF CT-CHIMNEY HEIGHTS			C	1,554	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				582	53		2	

Towns Served: BETHEL, DANBURY

Water System Facility and Sampling Point Inventory

<i>Water System</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	04724	BERKSHIRE INN - CHIM	A	Y			Y
		04725	BIG Y CHIM	A	Y		Y	Y
		04725D	BIG Y - CHIM - DOWNS	A	Y			
		04725U	BIG Y - CHIM - UPSTR	A	Y			
		04726	3 MECKAUER CIR SS	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		GWS001	11 STONY HILL ROAD	A	Y		Y	
		GWS002	157 ROCKWELL ROAD	A	Y	1		
		GWS003	17 FOX DEN ROAD	A	Y	3		
		GWS004	11 PARTRIDGE DRIVE	A	Y	3		
		GWS005	70 WALNUT HILL ROAD	A	Y	1		
		GWS006	2 HEARTHSTONE DR.	A	Y	3		
		GWS007	81 WALNUT HILL ROAD	A		3		
		GWS008	75 WALNUT HILL ROAD	A		3		
		GWS009	79 WALNUT HILL ROAD	A		3		
		GWS010	80 WALNUT HILL ROAD	A		3		
		GWS011	81 WALNUT HILL ROAD	A		3		
		GWS012	11 FAR HORIZONS DR	A		1		
		GWS013	4 FAR HORIZONS DR	A		1		
		GWS014	2 FAR HORIZONS DR	A		3		
		GWS015	23 FAR HORIZONS	A		3		
		GWS016	25 APPLETREE RD	A		1		
		GWS017	2 APPLETREE RD	A		1		
		GWS018	4 APPLETREE RD	A		1		
		GWS019	9 APPLETREE RD	A		1		
		GWS020	21 APPLETREE RD	A		1		
		GWS021	19 APPLETREE RD	A		1		
		GWS022	14 FAR HORIZONS	A	Y	1		
		GWS023	24 FAR HORIZONS	A	Y	3		
		GWS024	23 WIN SAP RUN	A	Y	1		
		GWS025	69 WALNUT HILL ROAD	A	Y	3		
		GWS026	74 WALNUT HILL ROAD	A	Y	3		
		GWS027	76 WALNUT HILL ROAD	A	Y	3		
		GWS028	84 WALNUT HILL ROAD	A	Y	3		
		GWS029	81 STONY HILL ROAD	A	Y			
		GWS030	87 STONY HILL ROAD	A	Y			
		GWS031	3 POND VIEW DRIVE	A			Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0098011	AQUARION WATER CO OF CT-CHIMNEY HEIGHTS			C	1,554	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				582	53		2	

Towns Served: BETHEL, DANBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB7060	9 PAYNE ROAD	A	Y	3		
		PB7061	3 PAYNE ROAD	A	Y	3		
		PB7062	27 MECKAUER CIRCLE	A	Y	3		
		PB7063	29 MECKAUER CIRCLE	A	Y	3		
		PB7064	8 MECKAUER CIRCLE	A	Y	3		
		PB7065	11 MECKAUER	A	Y	3		
		PB7148	23 WINE SAP RUN	A	Y	1		
		PB7149	PB7149 - 69 WALNUT H	A	Y			
		PB7151	70 WALNUT HILL RD	A	Y	1		
		PB7152	PB7152 - 74 WALNUT H	A	Y			
		PB7153	PB7153 - 84 WALNUT H	A	Y			
		PB7154	14 FAR HORIZONS DR	A	Y	1		
		PB7155	11 FAR HORIZONS DR	A	Y	1		
		PB7156	PB7156 - 24 FAR HORI	A	Y			
		PB7157	6 APPLETREE RD	A	Y	1		
		PB7158	PB7158 - 23 QUAKER R	A	Y			
		PB7872	17 APPLETREE RD	A		1		
		PB7891	72 WALNUT HILL RD	A		1		
		PB7892	12 COLONIAL DR	A		1		
		PB7893	30 PAYNE RD	A		1		
		PB7894	21 SHELTER ROCK RD	A		1		
		PB7895	21 WINE SAP RUN	A		1		
		PB7896	67 WALNUT HILL RD	A		1		
		PB7897	25 APPLETREE RD	A		1		
		PB7898	15 FAR HORIZONS DR	A		1		
		PB7899	17 COLONIAL DR	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1205	WELL 1	2	WELL 1	A				
51501	CHIMNEY HEIGHTS TANK							
558	CHIMNEY HEIGHTS TREATMENT PLANT							
57558	INTERCONNECTION - UW NEWTOWN							
59172	HIGH SERVICE PUMP STATION - WOODLAWN PS							
59424	INTERCONNECTION - CITY OF DANBURY WATER							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0098011	AQUARION WATER CO OF CT-CHIMNEY HEIGHTS			C	1,554	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				582	53		2	

Towns Served: BETHEL, DANBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
60647	INTERCONNECTION - DANBURY WATER							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LOTT, LESTER	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2021

Water System Facility: **CHIMNEY HEIGHTS TREATMENT PLANT (WSF ID: 558)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
TORRES, JR., MIGUEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2020
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2019

Contact Information

Name				Organization		Job Title			
Mr. John P. Walsh				Aquarion Water Company		Vice President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
600 Lindley Street			Mail Stop 250			Bridgeport		CT	06606
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
203-337-5852			203-337-5938			781-413-6175	jwalsh@aquarionwater.com		

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090114	ELMWOOD COURT LLC			C	54	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3				

Towns Served: BETHEL

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		Complete
	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/20	6/1-9/30	
	1/1/21 - 12/31/23	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Water System Facility: ENTRY POINT WELL #1 (WSF ID: 00700)			
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/17 - 12/31/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0090114	ELMWOOD COURT LLC			C	54	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: BETHEL

Monitoring Requirements

Water System Facility: ENTRY POINT WELL #1 (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/20 - 12/31/22		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #1 (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Water System Facility: ENTRY POINT WELL #2 (WSF ID: 00701)			
Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #2 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT WELL #2 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090114	ELMWOOD COURT LLC			C	54	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
					3			

Towns Served: BETHEL

Monitoring Requirements

Water System Facility: ENTRY POINT WELL #2 (WSF ID: 00701)

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT WELL #2 (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT WELL #2 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT WELL #2 (3)	1/1/18 - 12/31/18		
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT WELL #2 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT WELL #2 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT WELL #2 (3)	1/1/18 - 12/31/18		
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2010	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION EXEMPTION	3/1/2021	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Organic Chemicals M&R Violation	1/1/18 - 12/31/18	3	2/22/2020		3/3/2020	
Nitrate And Nitrite M&R Violation	1/1/18 - 12/31/18	3	2/22/2020		3/3/2020	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0090114	ELMWOOD COURT LLC			C	54	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
					3			

Towns Served: BETHEL

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		APR 5	APARTMENT 5	A	Y	2	Y	
		APT 5	APARTMENT 5	A	Y	2	Y	
		BUILD73NO1	BUILDING 73 NUMB 1	A	Y	2	Y	
		BUILD73NO2	BUILDING 73 NUMB 2	A	Y	2	Y	
		BUILD73NO3	BUILDING 73 NUMB 3	A	Y	2	Y	
		BUILD73NO4	BUILDING 73 NUMB 4	A	Y	2	Y	
		BUILD73NO5	BUILDING 73 NUMB 5	A	Y	2	Y	
		BUILD77NO1	BULDING 77 NUMB 1	A	Y	2	Y	
		BUILD77NO2	BULDING 77 NUMB 2	A	Y	2	Y	
		BUILD77NO3	BULDING 77 NUMB 3	A	Y	2	Y	
		BUILD77NO4	BULDING 77 NUMB 4	A	Y	2	Y	
		BUILD79NO1	BUILDING 79 NUMB 1	A	Y	2	Y	
		BUILD79NO2	BUILDING 79 NUMB 2	A	Y	2	Y	
		BUILD79NO3	BUILDING 79 NUMB 3	A	Y	2	Y	
		BUILD79NO4	BUILDING 79 NUMB 4	A	Y	2	Y	
		BUILD79NO5	BUILDING 79 NUMB 5	A	Y	2	Y	
		BUILD79NO6	BUILDING 79 NUMB 6	A	Y	2	Y	
		BUILD79NO7	BUILDING 79 NUMB 7	A	Y	2	Y	
		BUILD79NO8	BUILDING 79 NUMB 8	A	Y	2	Y	
		BUILD83NO1	BUILDING 83 NUMB 1	A	Y	2	Y	
		BUILD83NO2	BUILDING 83 NUMB 2	A	Y	2	Y	
		BUILD83NO3	BUILDING 83 NUMB 3	A	Y	2	Y	
		BUILD83NO4	BUILDING 83 NUMB 4	A	Y	2	Y	Y
		BUILD83NO5	BUILDING 83 NUMB 5	A	Y	2	Y	
		BUILD83NO6	BUILDING 83 NUMB 6	A	Y	2	Y	
		BUILD83NO7	BUILDING 83 NUMB 7	A	Y	2	Y	
		BUILD83NO8	BUILDING 83 NUMB 8	A	Y	2	Y	
		BUILDNO81	BUILDING NUMB 81	A	Y	2	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		LCAP4	LEAD COPPER APT 4	I	Y			
		LOT81	LOT 81 C/L	A	Y	2	Y	
		LOT83	APT 2 LOT 83	A	Y	2	Y	
		OFFSINK	OFFICE SINK	A	Y	2	Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT WELL #1	3	ENTRY POINT WELL #1	A				
00701	ENTRY POINT WELL #2	3	ENTRY POINT WELL #2	A				
1905	WELL #1	2	WELL	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0090114	ELMWOOD COURT LLC			C	54	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: BETHEL

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
1906	WELL #2	2	WELL #2	A				
55314	PRESSURE TANKS WELL #1							
55316	PRESSURE TANK WELL #2							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
HURLBUT, PAUL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019

Contact Information

Name		Organization		Job Title		
Mr. Gregory M. Kallas				Member		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
5 Bernlou Drive				Danbury	CT	06811
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-733-1983				203-792-6876	kallasfam@hotmail.com	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.